

NOTES:

- 1. ALL PIPE AND FITTINGS SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL OR BRASS.
- 2. WHERE REUSE SERVICE IS AVAILABLE, ALL CONNECTIONS TO THE CITY POTABLE WATER SUPPLY SHALL BE EQUIPPED WITH AN RPE BACKFLOW PREVENTER.

REDUCED PRESSURE BACKFLOW PREVENTER

NOT TO SCALE

